



浙江三花制冷集团有限公司

Zhejiang Sanhua Climate and Appliance Controls Group CO., LTD

Add: 358 West Xinchang Avenue,  
312500, Xinchang, Zhejiang, China

Tel: +86-575-86221102



## The UK Declaration of Conformity

Issued in accordance with

Pressure Equipment (Safety) Regulation 2016(2016/1105)

Electrical Equipment (Safety) Regulation 2016(2016/1101)

Electromagnetic Compatibility (Safety) Regulation 2016(2016/1091)

**The manufacturer's name and address:**

Company: Zhejiang Sanhua Climate and Appliance Controls Group Co., Ltd

Address: Xialiquan, Xinchang, 312500, Zhejiang, China

**Authorized Representative:** Ilan Peleg

**Authorized Company:** Sanhua International Europe S.L.

Tel: +34 91 654 46 92 Mob: +34 6 15 83 37 02 E-Mail: [Ilan@sanhuaeurope.com](mailto:Ilan@sanhuaeurope.com)

Address: C/ José Celestino Mutis, 4, 2I 28703 San Sebastian de los Reyes - Spain

### Section 1 - Pressure Equipment (Safety) Regulation 2016(2016/1105)

**Declaration:**

Pressure transmitter YCQ series shown in the tables below, are classified "Pressure accessories" in the sense of the Pressure Equipment (Safety) Regulation 2016(2016/1105), Article 2 point (5).

The Refrigerant proper to the Fluid Group I and II as defined in the article 3 (1) and 3 (2) of the Regulation 2016(2016/1105).

**Description of Products:**

TS (°C)	-30 to +120	Fluid Group I		Fluid Group II	
		Safety category	Part 3 – Pressure Equipment (Safety) Regulations 2016	Safety category	Part 3 – Pressure Equipment (Safety) Regulations 2016
Models	PS(bar)				
YCQB01Y XX	10	Art. 4.3	-	Art. 4.3	-
YCQB02Y XX	20	Art. 4.3	-	Art. 4.3	-
YCQB03Y XX	30	Art. 4.3	-	Art. 4.3	-
YCQB04Y XX	40	Art. 4.3	-	Art. 4.3	-
YCQB05Y XX	50	Art. 4.3	-	Art. 4.3	-

Table 1

TS (°C)	-40 to +80	Fluid Group I		Fluid Group II	
Models	PS(bar)	Safety category	Part 3 – Pressure Equipment (Safety) Regulations 2016	Safety category	Part 3 – Pressure Equipment (Safety) Regulations 2016
YCQC01Y XX	10	Art. 4.3	-	Art. 4.3	-
YCQC02Y XX	20	Art. 4.3	-	Art. 4.3	-
YCQC03Y XX	30	Art. 4.3	-	Art. 4.3	-
YCQC04Y XX	40	Art. 4.3	-	Art. 4.3	-
YCQC05Y XX	50	Art. 4.3	-	Art. 4.3	-

Table 2

TS (°C)	-40 to +125	Fluid Group I		Fluid Group II	
Models	PS(bar)	Safety category	Part 3 – Pressure Equipment (Safety) Regulations 2016	Safety category	Part 3 – Pressure Equipment (Safety) Regulations 2016
YQCB09L XX	90	NA	-	Art. 4.3	-
YQCB15L XX	150	NA	-	Art. 4.3	-
YCQC09L XX	90	NA	-	Art. 4.3	-
YCQC15L XX	150	NA	-	Art. 4.3	-

Table 3

x positions are variable

y position can be “H” or “L”

**Note:**

All the models listed in the table above classified as “Art. 4.3” aren’t subjected to the Essential Safety Requirements set out in the Pressure Equipment (Safety) Regulation 2016(2016/1105), Article 2 because their characteristics are below or equal to the limits fixed in Article 6 (c) (i) of the same Regulation. As mentioned in the Directive all these products have a nominal size “DN” below or equal to :

- a) 25mm for refrigerants belonging to Fluid Group I
- b) 32mm for refrigerants belonging to Fluid Group II

Therefore, according to requirements of Article 4 (1) (c) (i) them:

- Are designed and manufactured in accordance with a sound engineering practice in order to ensure safe use.

- Are accompanied by adequate instructions for use
- Bear markings to permit identification of the manufacturer
- Don't bear CE or UKCA marking referred to in Article 8
- Are not accompanied by a "Declaration of Conformity" to Pressure Equipment (Safety) Regulation 2016(2016/1105)

Covered by this declaration is in conformity with the following directives, standards or other normative documents, provided that the product is used in accordance with our instructions:

- BS EN 12284:2003 - Refrigerating systems and heat pumps. Valves. Requirements, testing and marking
- BS EN 378-2:2016 - Refrigerating systems and heat pumps. Safety and environmental requirements. Basic requirements, definitions, classification and selection criteria

## Section 2 - Electrical Equipment (Safety) Regulation 2016(2016/1101)

### **Declaration:**

Pressure transmitter YCQ series shown in the table 1-3, are in conformity to the following standards as required by the Electrical Equipment (Safety) Regulation 2016(2016/1101).

Covered by this declaration is in conformity with the following directives, standards or other normative documents, provided that the product is used in accordance with our instructions:

Automatic electrical controls for household and similar use – Part 1 : General requirements  
**(BS) EN 60730-1:2017-05 ; (BS) EN 60730-1:2016; (BS) EN 60730-1:2016/A1:2019;**

- **With sub-clauses 7/8/9/10/11/12/13/18/19/20/21/27**

Additional test has been performed in order to allow the usage of the present electrical device with Flammable refrigerants as described in the BS EN-378-1/2012-08 Annex F section F.2.3.

Household and similar electrical appliances – Safety

**(BS)EN 60335-2-24 :2019-11; (BS)EN 60335-2-24 :2010/A1:2019**

- **With sub-clauses 22.110**

Household and similar electrical appliances – Safety

**(BS)EN 60335-2-89:2018-10; (BS)EN 60335-2-89:2010/A2:2017**

- **With sub-clauses 22.109**

Household and similar electrical appliance – Safety

(Particular requirements for electrical heat pumps, air conditioner, dehumidifiers)

**(BS)EN 60335-2-40/2014-01**

**(BS)EN 60335-2-40/2003 + A11/2004 + A12/2005 + A1/2006 + A2/2009 + A13/2012**

- **With sub-clauses 22.116(no electrical component, which could be a source of ignition in case of normal operation or in the event of a leak)**
- **With sub-clauses 22.117 and Annex BB**

**Note:**

The applicability of the Equipment (Safety) Regulation 2016(2016/1101) is limited to the coil models with voltage rating of between 50 and 1000 V for alternating current and between 75 and 1500 V for direct current.

All the products excluded by the Equipment (Safety) Regulation 2016(2016/1101) respects the following requirements:

- Are designed and manufactured in accordance with a sound engineering practice in order to ensure safe use.
- Are accompanied by adequate instructions for use
- Bear markings to permit identification of the manufacturer
- Don't bear CE or UKCA marking referred to in Article 39
- Are not accompanied by a "Declaration of Conformity" to Equipment (Safety) Regulation 2016(2016/1101) - SCHEDULE8(Regulation 8)

**Section 3 -Electromagnetic Compatibility (Safety) Regulation 2016(2016/1091)**

**Declaration:**

The Products specified by "Description" fulfill the requirements of above UK Regulation and is in line with below mentioned BS standards. Unauthorized modifications will make this declaration invalid.

**Description:**

1. Pressure transmitter YCQB series

Applicable Standards for Testing:

Test Item	Basic standards	Results
Radiated Emissions	BS EN 55011:2009+A1:2010/CISPR11:2009+A1:2010	Complied
Conducted Emissions	BS EN 55011:2009+A1:2010/CISPR11:2009+A1:2010	Complied
Electrostatic discharge immunity test	BS EN 61000-4-2: 2009	Complied
Radiated, radio-frequency, electromagnetic field Immunity	BS EN 61000-4-3:2006, +A1:2007, +A2:2010	Complied
Electrical fast transient/burst immunity	BS EN 61000-4-4: 2012	Complied
Immunity to conducted disturbances, induced by radio-frequency fields	BS EN 61000-4-6: 2014	Complied

2. Pressure transmitter YCQC series

Applicable Standards for Testing:

Test Item	Basic standards	Results
Electrostatic discharge immunity test	BS EN 61000-4-2: 2009	Complied
Testing and measurement techniques- Surge immunity test	BS EN 61000-4-5:2014	Complied
Electrical fast transient/burst immunity	BS EN 61000-4-4: 2012	Complied
Immunity to conducted disturbances, induced by radio-frequency fields	BS EN 61000-4-6: 2014	Complied
Radiated, radio-frequency, electromagnetic field Immunity	BS EN 61000-4-3:2006, +A1:2007, +A2:2010	Complied

Responsible Person to issue the declaration of Conformity:	Date	Signature
Mr. Zhouyang Li	2021.5.27	

